


The curves reflect maximum performance characteristics without exceeding full load (Nameplate) horsepower. All pumps have a service factor of 1.2. Operation is recommended in the bounded area with operational point within the curve limit. Performance curves are based on actual tests with clear water at 70° F. and 1280 feet site elevation.

Conditions of Service:

GPM:_____ TDH:_____



Dimensional SK75/100 Data



All dimensions in inches. Metric for international use. Component dimensions may vary \pm 1/8 inch. Dimensional data not for construction purpose unless certified. Dimensions and weights are approximate. On/Off level adjustable. We reserve the right to make revisions to our product (s) and the product (s) specifications without notice.






MODEL: SK75, Sewage Ejector

R.P.M.	1750
MOTOR TYPE	OIL FILLED WITH AUTOMATIC RESET THERMAL OVERLOAD
MOTOR PROTECTION	AUTOMATIC RESET / THERMAL OVERLOAD

SK75

HP	VOLTAGE	PHASE	NEC CODE	SERVICE FACTOR	FULL LOAD AMPS
3/4	200	1	-	1	10.4
3/4	230	1	-	1	9.0
3/4	200	3	-	1	4.0
3/4	230	3	-	1	3.5
3/4	460	3	-	1	1.8
3/4	575	3	-	1	1.44






Electrical Data

MODEL: SK75, Sewage Ejector

R.P.M.	1750
MOTOR TYPE	OIL FILLED WITH AUTOMATIC RESET THERMAL OVERLOAD
MOTOR PROTECTION	AUTOMATIC RESET / THERMAL OVERLOAD

SK100

HP	VOLTAGE	PHASE	NEC CODE	SERVICE FACTOR	FULL LOAD AMPS
1	200	1	-	1	11.5
1	230	1	-	1	10.0
1	200	3	-	1	5.0
1	230	3	-	1	4.4
1	460	3	-	1	2.2
1	575	3	-	1	1.7





MODEL: SK75, Sewage Ejector

SK75

Physical Data:

DISCHARGE SIZE	2" NPT (STANDARD) 3" NPT (OPTIONAL)
SOLIDS SIZE	2"
IMPELLER TYPE	2 VANE NON CLOG
CABLE LENGTH	20' STANDARD
PAINT	PAINTED AFTER ASSEMBLY, DARK GREEN, WATER REDUCIBLE ENAMEL, ONE COAT, AIR DRIED.

Temperature:

MAXIMUM LIQUID	140°F
MAXIMUM STATOR	
OIL FLASH POINT	

Technical Data:

POWE	ER CORD TYPE	STW-A
μZ	MOTOR HOUSING	CAST IRON
	CASING	CAST IRON
MATERIALS OF CONSTRUCTION	IMPELLER	CAST IRON
STF	MOTOR SHAFT	416 STAINLESS STEEL
AAT ON:	HARDWARE	STAINLESS STEEL
2 Ö	"O" RINGS	BUNA - N
MECHANICAL SEALS		
Standard:		CARBON / CERAMIC
UPPER BEARING		SINGLE ROW-BALL
LOWER BEARING		SINGLE ROW-BALL

MODEL: SK100, Sewage Ejector

Physical Data:

DISCHARGE SIZE	2" NPT (STANDARD) 3" NPT (OPTIONAL)
SOLIDS SIZE	2"
IMPELLER TYPE	2 VANE NON CLOG
CABLE LENGTH	20' STANDARD
PAINT	PAINTED AFTER ASSEMBLY, DARK GREEN, WATER REDUCIBLE ENAMEL, ONE COAT, AIR DRIED.

Temperature:

MAXIMUM LIQUID	140°F
MAXIMUM STATOR	
OIL FLASH POINT	

Technical Data:

POWE	ER CORD TYPE	STW-A
μZ	MOTOR HOUSING	CAST IRON
l ⊇ E	CASING	CAST IRON
MATERIALS OF CONSTRUCTION	IMPELLER	CAST IRON
STF	MOTOR SHAFT	416 STAINLESS STEEL
NAT ON:	HARDWARE	STAINLESS STEEL
2 Ö	"O" RINGS	BUNA - N
MECHANICAL SEALS		
	Standard:	CARBON / CERAMIC
UPPER BEARING		SINGLE ROW-BALL
LOWER BEARING		SINGLE ROW-BALL



SUBMERSIBLE SEWAGE EJECTOR MODELS: SK75 and SK100

SK/5/100

1.01 GENERAL

Contractor shall furnish all labor, materials, equipment and incidentals required to provide (Qty.) submersible centrifugal sewage ejector pump(s) as specified herein. The pump models covered in this specification are the SK75, and SK100. The pump furnished for this application shall be MODEL ______ as manufactured by Hydromatic Pumps.

2.01 **DESIGN CONDITIONS**

Each pump shall be rated _____ H.P., _____ volts, _____ phase, _____ hertz and operate at _____ RPM.

3.01 **OPERATING CONDITIONS**

The pump shall deliver ______ U.S. GPM/LPS at ______ feet/meters TDH, and handle a ______ inch solid. The curve submitted for approval shall state, in addition to head and capacity performance, solid handling capability, amp rating, and design impeller diameter.

4.01 CONSTRUCTION

Each pump shall be of the sealed submersible type, incorporating features normally found in pumps furnished for the residential market.

These features include:

- 1. The pump volute, motor, and seal housing shall be high quality gray cast iron, ASTM A-48, Class 30.
- 2. The pump inlet shall be open and clear, without screening to provide access for sewage and solids.
- 3. All external mating parts shall be machined and Buna N, O-Ring sealed.
- 4. All fasteners exposed to the pumped liquid shall be 300 series stainless steel.
- 5. All power cords shall be water resistant UL or CSA approved, with double insulation, and sized as a function of Amp. draw.

5.01 MOTOR AND SHAFT

The stator, rotor and bearings shall be mounted in a sealed submersible type housing. Single phase motors shall be split phase or capacitor start with centrifugal switch. Three phase motors shall be Polyphase. Full Load and Locked Rotor Amps as well as Start and Run winding resistance shall be tabulated for each pump.

6.01 BEARINGS, SHAFT AND MECHANICAL SEAL

An upper bushing bearing and lower thrust bearing shall be required. The upper bearing shall be brass while the lower bearing is a single row ball. They are both permanently and continuously lubricated and cooled by the dielectric oil which fills the motor housing. The motor shaft shall be stainless steel and sealed from the pumped liquid with a carbon ceramic mechanical seal.



7.01 **IMPELLER**

The Impeller shall be high capacity, two vane, non-clog design with pump out vanes on the back side. These vanes wash out grit and stringy material that will damage the shaft and mechanical seal.

8.01 AUTOMATIC CONTROL

All single phase pumps should be capable of automatic operation.

<u>SK75/100</u>

9.01 MANUAL CONTROL

The Single Phase SK75 and SK100 pumps are not supplied with any type of automatic control. A super or double wide angle piggy-back float switch can be supplied and fitted to these pumps.

10.01 PAINTING

All cast iron parts shall be painted before assembly with a water reducible alkyd air dried enamel. The paint shall be applied in one coat with a minimum thickness of 3 to 4 mils.

11.01 **TESTING**

All pumps shall be individually tested to include the following:

- 1. The pump and power cord shall be visually inspected for imperfections, cuts or nicks.
- 2. The pump shall have a ground continuity check and the motor chamber shall be Hi-potted to test for moisture content and/or insulation defects.
- 3. The motor and volute housing shall be pressurized and a 10 second air leak decay test run.
- 4. Oil is added, and the pump is run. Voltage and current are monitored visually, electronically, and the tester listens for any noise or malfunction.

