



NO.	ELEV.	DESCRIPTION
1		72 IN X 144 IN FRP WET WELL
	2000.00	RIM
	1988.00	BASE
2		60IN X 60 IN FRP VALVE VAULT
	1995.00	BASE
3	1994.00	IE - 10 IN INLET HUB FOR 6 IN SDR 35 PVC PIPE
		9:00 POSITION
4	1996.00	IE - 4 IN SCH 10 STAINLESS STEEL OUTLET
		3:00 POSITION
5		HYDROMATIC S4MVXP1000 PUMPS, 10 HP, 460V/3
		EXPLOSION-PROOF, 300 GPM @ 40 FT TDH
		SHIPPED LOOSE
6		HYDROMATIC 4 IN MTM DISCHARGE ELBOW
7		4 IN SCH 10 STAINLESS STEEL DISCHARGE MANIFOLD
8		2 IN SCH 40 STAINLESS STEEL SLIDE RAILS
9		LEVEL FLOAT SWITCHES
	1993.50	HIGH LEVEL ALARM
	1993.30	LAG PUMP ON
	1993.00	LEAD PUMP ON
	1991.00	PUMP(S) OFF
10		2 IN SCH 40 PVC DRAIN
11		4 IN LEVER AND WEIGHT CHECK VALVE
12		4 IN RESILIENT SEAT GATE VALVE
13		LADDER
14		ELECTRICAL HAND HOLE JUNCTION BOX ASSEMBLY
		SHIPPED LOOSE
15		300 PSF ALUMINUM HATCHES
16		CONCRETE ANTI-FLOTATION RING - IN WIDE X
		IN TALL - YDS - BY OTHERS
17		#4 REBAR REINFORCEMENT - BY OTHERS
18		12 IN COMPACTED BASE - BY OTHERS
19		DUPLEX ALTERNATING COTROL PANEL (NOT SHOWN)
		SHIPPED LOOSE

AFS-STN-72-144-60-40-40-SS-EXT
 PROJECT NAME - PROJECT # 12345
 PACKAGED LIFT STATION

DWG NO.	DATE	SCALE	DRAWN BY	CHECKED BY
XXX	11/2/16	1:36	RJK	N/A

AFS
 AUTOMATED FLOW SYSTEMS
 625 BEST AVE
 COEUR D'ALENE, ID 83814
 PHONE 208.664.2133

4101 E BROADWAY
 SPOKANE, WA 99202
 PHONE 509.534.5616

WWW.RCWORST.COM

CUSTOMER APPROVAL: _____ DATE: _____
 BY THIS SIGNATURE, CUSTOMER INDICATES THAT HE HAS REVIEWED THIS SUBMITTAL DRAWING AND FOUND THAT IT MEETS ALL OF THE DESIGNER'S FUNCTIONAL REQUIREMENTS AND/OR SPECIFICATIONS. CUSTOMER HEREBY AUTHORIZES RC WORST & CO. INC. TO MANUFACTURE THE CUSTOM PRODUCT IN ACCORDANCE WITH THIS SUBMITTAL DRAWING.