
## **Splice Box Wiring Diagram**

To Terminal

To Terminal



814 AIRWAY AVENUE



Heat Shrink & Butt Connector \*

\* Refer to drawing EIN-SB-SB-1 for splicing instructions.



FACSIMILE:

(541) 459-2884

## **Float Tag Colors**

Y - Yellow

P - Purple

**B** - Blue

**G** - Green

R - Red

Orange

E - Grey

**W** - White

Note: Multi-function floats will have more than one marker

**Attention:** Failure to follow splicing instructions will void warranty

Control Panel Series

P

**Float Function Color Code** 

**Splice Box Model** 

**Cord Grip**Hand tighten each cord grip

so that the cord will not easily

slide through the grommet.

Redundant Off & Low Level Alarm

Lead Pump On &

Pumps Off

W

To Terminal

To Terminal

Drawing No.

SB4

EDW-SB-DAX-524

EDW-SB-DAX-524 Rev 1.1 ©04/30/98

DAX IR2 RO (YPGW)

Lag Pump On

**High Level Alarm** 

**YPGW**