Float Arrangement Diagram

Y(PG)R Y(PB)(PR)R (YPG)R • Factory Standard • 814 AIRWAY AVENUE SUTHERLIN, OREGON TL* TL* TL* 12345 12345 1 2 3 4 5 Terminal Strip Terminal Strip Terminal Strip **Float Types** 97479-9012 High Level Alarm High Level Alarm **Typical Orenco float model:** A High Level Alarm / Y-Yellow Y-Yellow Timer Override Specs: contact - normally open TELEPHONE: On & Off differential - no minimum (YPG)-Yellow / power rating - signal 3" Min. (541) 459-4449 Purple & Green Possible substitutions: B.C.D Timer Override Timer Override On On & Off (PB)-Purple & Blue FACSIMILE: (PG)-Purple & Green Typical Orenco float model: B (541) 459-2884 Specs: contact - normally open Timer Override Off differential - 3" min. (PR)-Purple & power rating - signal 3" Min. Red Possible substitutions: C,D Timer On & Off Timer On & Off Timer On & Off **R-Red R-Red R-Red** 👕 Typical Orenco float model: T Specs: contact - normally closed 3" Min. 3" Min.(3" Min. differential - no minimum power rating - signal *Remove pre-installed Terminal Link Rail *Remove pre-installed Terminal Link Rail *Terminal Link Rail is required (factory from terminals. See Panel Wiring Diagram from terminals. See Panel Wiring Diagram Installed). for instructions. for instructions. For a wire splicing illustration of the above For a wire splicing illustration of the above For a wire splicing illustration of the above diagram, request one of the following Splice diagram, request one of the following Splice diagram, request one of the following Splice Box Wiring Diagrams: Box Wiring Diagrams: Box Wiring Diagrams: EDW-SB-DAX-25 (no pump cords) EDW-SB-DAX-22 (no pump cords) EDW-SB-DAX-19 (no pump cords) EDW-SB-DAX-26 (one pump cord) EDW-SB-DAX-23 (one pump cord) EDW-SB-DAX-20 (one pump cord) EDW-SB-DAX-27 (two pump cords) EDW-SB-DAX-24 (two pump cords) EDW-SB-DAX-21 (two pump cords)

Check the appropriate box for the float function (color code) used in your system.

Control Panel Series

DAX PT



