

MVP-S DM CS Operation

Oreco's Most Versatile Panel (MVP) line of control panels includes an easy-to-use programmable logic unit that incorporates many timing and logic functions. This panel will accommodate timed dosed or on-demand systems. The panel's default mode of operation is timed dose. This document describes each mode of operation.

Alarm and Data Screens:

Alarm and data screens have been included with the panel to assist with panel monitoring and troubleshooting. The following alarm and data screens have been included in your panel, look for the √ to determine if the screen will be displayed for timed dosed or on-demand modes. Navigation between the screens is accomplished by using the up and down arrow keys. See "Screen Navigation" section for more details.

Screen	Description	Timed	Demand	Data Type*
Alarm Screens†				
1	Pump fail alarm	√	√	
2	High level alarm	√	√	
3	Low level alarm	√	√	
Data Screens				
4	Float status and timer mode (default screen, see fig 1)	√	√	
5	Pump cycles at top of screen and pump run time beneath	√	√	T
6	High level alarms at top of screen and low level alarms beneath	√	√	T
7	Override cycles at top of screen and timer float events beneath	√		T
8	Power faults at top of screen and hours in service beneath	√	√	T
9	Pump cycles at top of screen and pump run time beneath	√	√	R
10	High level alarms at top of screen and low level alarms beneath	√	√	R
11	Override cycles at top of screen and timer float events beneath	√		R
12	Power faults at top of screen and time since last reset beneath	√	√	R

† Alarm screens will only be displayed when alarms are active and include a date and time stamp of when the alarm started.

* Screens with "T" in the lower right corner have totaled values for the data. Screens with "R" in the lower right corner have resettable data and display the accumulated values since the last reset. To reset the accumulated values, hold the silence button on the panel for 10 seconds.

Float Status and Timer Mode Screen:

This default screen will display the condition of the floats and the operation mode of the panel. If the floats are lifted out of sequence, this screen will display “Float Error” while showing the float status.




Figure 1. Float Status and Timer Mode Screen

Digital Input and Digital Output Screens:

The unit will activate various inputs and outputs as it operates (see Figure 2).




Figure 2. Input & Output Screens

Knowing what conditions cause the inputs and outputs to activate can be a helpful installation and troubleshooting tool. The input functions will vary based on the mode of operation of the panel. The following inputs and outputs have been used with your panel:

#	Functions:	Activation Conditions:
Inputs (Timed Dose Mode)		
1	Redundant Off & Low Level Alarm Float	Float in up position
2	Timer On & Off Float	Float in up position
3	Override Timer On & Off Float	Float in up position
4	High Level Alarm Float	Float in up position
5	Current Sensor	Pump is activated
6	Push To Silence/Reset	Pushbutton is pressed
Inputs (On-Demand Mode)		
1	Redundant Off & Low Level Alarm Float	Float in up position
2	Off Float	Float in up position
3	On Float	Float in up position
4	High Level Alarm Float	Float in up position
5	Current Sensor	Pump is activated
6	Push To Silence/Reset	Pushbutton is pressed
Outputs		
1	Pump	Pump is called to run
2	Level Alarm Light	Level Alarm Light is activated
3	Pump Fail Light	Pump Fail Light is activated
4	Audible Alarm	Audible Alarm is activated

Screen Navigation:

The screens are arranged in the order shown in Figure 3 below. To move between screens, use the four arrow keys. The screens of interest are shown in bold. Additional built-in screens will be present, but do not contain useful information.




Figure 3. Screen Layout

Panel Operation:

This panel supports two different modes of operation based on selected parameter settings. See the “Setting Instructions” for this panel for information on how to change the mode of operation and other adjustable parameters.

Timed Dose (Default Operation):

Your control panel can perform the float functions listed below. Depending on the number of floats for your application, some functions may be omitted or combined.

High Level Alarm: This float activates the alarm light (steady) and audible alarm when lifted for longer than the high level alarm delay. The audible alarm may be silenced by pressing the illuminated PUSH TO SILENCE button on the front of the control panel. The alarm light (steady) will remain on until the float is lowered, and the audible alarm will reactivate in 12 hours if condition is not corrected.

Override Timer On & Off: This float activates the override timer function when lifted for more than two seconds. This timer function controls the pump cycles during high flow conditions. The override timer function will remain active until the float has lowered and the override timer minimum run time is completed. When the override timer function has been completed, normal timer operation will resume.

Timer On & Off: This float activates the timer function when lifted. The timer will be activated while the float is up and will be deactivated 30 seconds after the float is lowered. This timer function controls the pump cycles during normal flow conditions. Note: The timer will start with its off cycle.

Redundant Off & Low Level Alarm: This float turns off the pump when lowered for more than two seconds. This float is a secondary off float, which will operate if the Timer On & Off float fails. Pumping will be disabled in both the automatic and manual modes. This float also activates the alarm light (flashing) and audible alarm. The audible alarm may be silenced by pressing the illuminated PUSH TO SILENCE button on the front of the control panel. The alarm light will remain flashing until the float is lifted, and the audible alarm will reactivate in 12 hours if condition is not corrected.

Current Sensor: The current sensor is activated when the pump is called on to run. If the pump does not become activated in 2 seconds a pump failure will occur, which will activate the pump fail alarm light and audible alarm. The audible alarm may be silenced by pressing the illuminated PUSH TO SILENCE button on the front of the control panel. The pump fail light may be reset by pushing the PUSH TO RESET button, on the front of the control panel, after the pump fail condition has been corrected. If the alarm condition is not corrected in 12 hours, the audible alarm will be reactivated.

On-Demand:

Your control panel can perform the float functions listed below. Depending on the number of floats for your application, some functions may be omitted or combined.

High Level Alarm: This float activates the alarm light (steady) and audible alarm when lifted for longer than the high level alarm delay. The audible alarm may be silenced by pressing the illuminated PUSH TO SILENCE button on the front of the control panel. The alarm light (steady) will remain on until the float is lowered, and the audible alarm will reactivate in 12 hours if condition is not corrected.

Pump On: This float activates the pump when lifted. The pump will run for the minimum run time or until the pump off float (if used) is lowered.

Pump Off: This float turns off the pump when lowered if the minimum run time has elapsed.

Redundant Off & Low Level Alarm: This float turns off the pump when lowered for more than 2 seconds. This float is a secondary off float, which will operate if the Pump Off float fails. Pumping will be disabled in both the automatic and manual modes. This float also activates the alarm light (flashing) and audible alarm. The audible alarm may be silenced by pressing the illuminated PUSH TO SILENCE button on the front of the control panel. The alarm light will remain flashing until the float is lifted. If the alarm condition is not corrected in 12 hours, the audible alarm will be reactivated.

Current Sensor: The current sensor is activated when the pump is called on to run. If the pump does not become activated in 2 seconds a pump failure will occur, which will activate the pump fail alarm light and audible alarm. The audible alarm may be silenced by pressing the illuminated PUSH TO SILENCE button on the front of the control panel. The pump fail light may be reset by pushing the PUSH TO RESET button, on the front of the control panel, after the pump fail condition has been corrected. If the alarm condition is not corrected in 12 hours, the audible alarm will be reactivated.