Splice Box Wiring Diagram

To Terminal

To Terminal



814 AIRWAY AVENUE

SUTHERLIN, OREGON


97479-9012

TELEPHONE:

(541) 459-4449

FACSIMILE:

(541) 459-2884



* Refer to drawing EIN-SB-SB-1 for splicing instructions.

Float Tag Colors

V - Yellow

P - Purple

- Blue

- Green

R - Red

- Orange

- Grey

W - White

Note: Multi-function floats will have more than one marker

Attention: Failure to follow splicing instructions will void warranty

Control Panel Series

P

High Level Alarm

Lag Pump On

Float Function Color Code

Splice Box Model

Cord Grip Hand tighten each cord grip

so that the cord will not easily

slide through the grommet.

Redundant Off & Low Level Alarm

Lead Pump On &

Pumps Off

W

To Terminal

To Terminal

Drawing No.

DAX RO **YPGW** SB4

EDW-SB-DAX-66

EDW-SB-DAX-66

Rev 1.1 © 05/01/98